

# LUXURY CONCRETE 防滑認證報告

## 三大國際標準防滑測試結果

材料	面漆組合	DIN 51130	等級	DIN 51097	等級	UNE-ENV 12633 Rd	等級
Concrete Stone	2 coats Concrete Finish DSV	26.0°	R11	32°	Group C	50	Class 3
Concrete Floor	2 coats Concrete Finish DSV	4.1°	—	24°	Group B	19	Class 1
Concrete Floor L	2 coats Concrete Finish DSV	29.4°	R12	35°	Group C	63	Class 3
Concrete Stone	2 Primacrete Finish + 2 Concrete Finish WT	18.1°	R10	26°	Group C	36	Class 2
Concrete Floor	同上	1.8°	—	15°	Group A	12	Class 0
Concrete Floor	1 Primacrete Finish + 1 Concrete Finish WT	13.6°	R10	—	—	46	Class 2
Concrete Floor L	1 Primacrete Finish + 2 Concrete Finish WT	7.3°	R9	17°	Group A	25	Class 1

### 標準說明

- DIN 51130 — 油面傾斜防滑測試 (R9=6-9°、R10=10-19°、R11=19-27°、R12=27-35°、R13= $\geq$ 35°)
- DIN 51097 — 濕面防滑測試 (Group A  $\leq$ 12°、Group B  $\leq$ 18°、Group C  $\leq$ 24° 為最高等級)
- UNE-ENV 12633 — 滑動阻力 (Class 0 Rd<15、Class 1 15-35、Class 2 35-45、Class 3 Rd>45 為最高等級)

出具：Luxury Concrete, S.L. (CIF B98177538, Valencia, Spain)